



## ADDENDUM NUMBER TWO

**PROJECT:** MONTANA FISH WILDLIFE AND PARKS

CONCESSION KITCHEN EXPANSION WHITEHALL, MT

FWP #7186601

**DATE:** MARCH 10, 2020

**DISTRIBUTION:** TO ALL BIDDERS AND PLAN HOLDERS OF RECORD

Acknowledge the receipt of this Addendum by inserting its number and date in your proposal. Failure to do so may subject the bidder to disqualification. This Addendum forms a part of the Contract Documents as if bound therein, and modifies them as follows:

---

### AMMENDMENTS TO THE PROJECT MANUAL

1. The bid date has been modified. The new bid date will be Thursday, March 19<sup>th</sup>, 2020 at 3:00 P.M.

### CLARIFICATIONS TO THE DRAWINGS

1. An alternate monolithic foundation system may be used for the addition. See attached drawing for clarification. Use Myard PNP153544 bearing pads, or approved equal, for stair and deck footings. Bearing pad should be installed on 12" of compacted gravel fill.
2. 2" Rigid insulation should be installed under the slab and around thickened edges of the monolithic slab and up to grade at the exterior.

### SUPPLEMENTAL INFORMAITON

1. No Supplemental information in this addendum.

